

**APPENDIX J**

**AIR DISPERSION MODELING REPORT**

**ALBERTA ENVIRONMENTAL PROTECTION & ENHANCEMENT ACT  
AGRIUM JOFFRE RENEWAL APPLICATION  
APPROVAL NUMBER 9998-01-00**

**APPENDIX CONTENTS:**

**Air Dispersion Modeling Report**

THIS PAGE LEFT INTENTIONALLY BLANK



March 16, 2007

J2007-48

Agrium Products Inc.  
Box 666  
Red Deer, Alberta T4N 5G6

Attention: Mr. Will Kanda, Process Engineer, P.Eng.

**Subject: Dispersion Modelling for Agrium Products Inc.  
Joffre Nitrogen Operation Plant and Chigwell Distribution Terminal  
LSD 07-03-039-25 W4M and 07, 08, 09 and 10-34-040-25 W4M**

As requested, Calvin Consulting Group Ltd. (Calvin Consulting) completed dispersion modelling for the Agrium Products Inc. (Agrium) Joffre Nitrogen Operation (JNO) Plant and Chigwell Distribution Terminal (CDT), which are located at LSD 07-03-039-25 W4M and LSDs 07, 08, 09 and 10-34-040-25 W4M, respectively. Other NO<sub>x</sub> emission sources within 7 km of the JNO Plant were also included in the dispersion modelling. It should be noted that there are no other NO<sub>x</sub> emission sources within the CDT modelling domain.

### **Modelling Approach and Emission Parameters**

Information describing the normal operation and various flaring scenarios was provided by Agrium. Stack and emission parameters associated with the JNO Plant and CDT sources and other sources within the JNO 7 km modelling domain are shown in the following tables:

- **Table 1.** Stack and emission parameters for the Agrium JNO Plant and CDT point sources.
- **Table 2.** Fugitive emission rates associated with the Agrium JNO Plant and CDT.
- **Table 3.** Stack and emission parameters for other sources in the JNO Plant modelling domain.

The dispersion modelling was performed as per the latest Alberta Environment (AENV) Air Quality Model Guidelines, the U.S. EPA ISC-PRIME model, five years of meteorology data from the Red Deer Airport and complex terrain using the following receptor grids:

- Every 20 m out to 200 m
- Every 50 m out to 500 m
- Every 250 m out to 2500 m
- Every 500 m out to 5000 m
- Every 1000 m out to 7000 m
- Every 20 m along the perimeter fenceline
- Every 20 m out to 200 m surrounding the maximum predicted concentration obtained from the previous runs

Table 1. Stack and emission parameters for the Agrium JNO Plant and CDT point sources.

Source ID and Type	No. of Sources	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Temp (°C)	NO <sub>x</sub> Emission Rate (g/s)	NH <sub>3</sub> Emission Rate (g/s)
<b>JNO Plant</b>							
Steam Superheater / Boiler Stack (J-1)	1	45.6	2.22	2.94	365	1.296	0
<b>CDT – Normal</b>							
Flare Stack (C-1)	1	15.2	0.2	0.0027	711	0.0003	0
<b>CDT – Sphere Vapour to Flare</b>							
Flare Stack (C-1)	1	15.2	0.2	21.41	2094	4.408	8.3
<b>CDT – Rail Car Venting to Flare</b>							
Flare Stack (C-1)	1	15.2	0.2	69.93	2079	14.655	27.8

Table 2. Fugitive emission rates associated with the Agrium JNO Plant and CDT.

Location and Type	Total Area (m <sup>2</sup> )	NH <sub>3</sub> Emission Rate (g/s)
<b>JNO Plant</b>		
Ammonia Fugitive Emission Area	24,019	0.504
<b>CDT</b>		
Ammonia	13,332	0.957

Table 3. Stack and emission parameters for other sources in the JNO Plant modelling domain.

Source ID and Type	No. of Sources	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Temp (°C)	NO <sub>x</sub> Emission Rate (g/s)
<b>INEOS Joffre Flare Stacks</b>						
Q5980	1	61	1.01	91.4	618	0.0444
<b>INEOS Joffre Heaters / Furnaces</b>						
F5901	1	42.2	2.61	5.35	310	1.2565
F5902	1	42.2	2.61	4.28	308	1.6919
F5601	1	42.2	1.52	7.24	347	0.4722
F5907	1	34.7	0.956	2.73	259	0.1389
F5903	1	6.426	1.03	0.72	870	0.0417
<b>Nova Flare Stacks</b>						
FS749 – E1 Flare Stack	1	76.3	1.22	0.016	1000	0.054
FS745 – E2 Flare Stack	1	76.3	1.22	0.016	1000	0.096
FS734 – E2 Vapour Comb. Unit	1	13.72	2.13	2.4	605	0.072
93S001 – HOG Flare Stack	1	50.29	0.902	0.010	1000	0.181
FS761 – E3 Primary Flare Stack	1	83.8	0.91	0.056	1000	0.182
FS763 – E3 Secondary Flare Stack	1	83.8	0.91	0.005	1000	0
51S001 – PE1 Flare Stack	1	50.29	0.902	1.27	1000	0.528
105S001 – PE2 Flare Stack	1	50.29	0.902	0.015	1000	0.068
105FH001 – PE2 V/L Comb. Unit	1	17.3	2.13	7.49	851	0.182
FS409 – Co-Products Flare Stack	1	13.72	2.08	2.21	604	0.075
<b>Nova Heaters and Furnaces</b>						
H101 – Cracking Furnace	1	67.1	2.03	6.6	262	2.250
H102 – Cracking Furnace	1	67.1	2.03	6.6	262	2.250
H103 – Cracking Furnace	1	67.1	2.03	6.6	262	2.250
H104 – Cracking Furnace	1	67.1	2.03	6.6	262	2.250
H105 – Cracking Furnace	1	67.1	2.03	6.6	262	2.250
H106 – Cracking Furnace	1	67.1	2.03	6.6	262	2.250
H107 – Cracking Furnace	1	34.4	1.52 x 1.68 <sup>(a)</sup>	9.2	156	1.522
H108 – Cracking Furnace	1	34.4	1.52 x 1.68 <sup>(a)</sup>	9.2	156	1.522
H109 – Cracking Furnace	1	34.4	0.91 x 1.12 <sup>(a)</sup>	16	170	1.359
WHB601 – E1 Recovery Boiler	1	15.24	3.05	15.5	214	5.749
FB901A – E1 Steam Boiler	1	10.67	2.34	3.1	149	1.174
FB901B – E1 Steam Boiler	1	10.67	2.34	3.1	149	1.174
SH902A – Super Heater	1	27.74	1.75	2.4	279	0.657
H902B – Super Heater	1	27.74	1.75	2.4	279	0.657
H141 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H142 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H143 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H144 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H145 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H146 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H147 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568

Continued...

Table 3. Concluded.

Source ID and Type	No. of Sources	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Temp (°C)	NO <sub>x</sub> Emission Rate (g/s)
H148 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H149 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H150 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
H151 – Cracking Furnace	1	33.5	0.91 x 1.12 <sup>(a)</sup>	16.6	187	1.568
WHB605 – Recovery Boiler	1	19.5	3.05	17.4	149	9.038
FB905 – E2 Steam Boiler	1	15.24	1.82	5.4	150	1.565
H210 – Cracking Furnace	1	61	2.6	7.6	150	2.617
H220 – Cracking Furnace	1	61	2.6	7.6	150	2.617
H230 – Cracking Furnace	1	61	2.6	7.6	150	2.617
H250 – Cracking Furnace	1	61	2.6	7.6	150	2.617
H240 – Cracking Furnace	1	61	2.6	7.6	150	2.617
H260 – Cracking Furnace	1	61	2.6	7.6	150	2.617
H270 – Cracking Furnace	1	61	2.6	7.6	150	2.617
63ME001 – PE1 Boiler	1	10.67	1.07	2	180	0.096
63ME011 – PE1 Boiler	1	10.67	1.07	2	180	0.096
CT101 – Turbine (167000 kW)	1	45.7	5.5	21	82	10.046
CT201 – Turbine (167000 kW)	1	45.7	5.5	21	82	10.046
Cogen Steam Boiler	1	19.8	1.37	14.68	149	1.806
<b>Area Source</b>						
INEOS Flare Pit (Area = 180.3 m <sup>2</sup> )						0.0095

<sup>(a)</sup> Rectangular Opening  
Concluded.

### Modelling Results for JNO

The modelling results for continuous operations associated with the Agrium JNO Plant and other facilities that emit NO<sub>x</sub> in the JNO Plant modelling domain are presented in Table 4. The maximum overall NO<sub>x</sub> concentration is 747.07 µg/m<sup>3</sup> (0.396 ppm). Using the Ozone Limiting Method as per the latest AENV Model Guideline, this corresponds to an overall maximum predicted hourly average ground-level NO<sub>2</sub> concentration of 169.0 µg/m<sup>3</sup> (0.090 ppm). This concentration is predicted to occur 5758 m northwest of the steam superheater and auxiliary boiler stack (J-1) and does not exceed the allowable Alberta Ambient Air Quality Guideline (AAAQG) of 400 µg/m<sup>3</sup> (0.212 ppm) for NO<sub>2</sub>. Figure 1 shows the maximum predicted NO<sub>2</sub> concentrations over the entire modelling domain.

The maximum predicted hourly average ground-level NH<sub>3</sub> concentration associated with the Agrium JNO facility is 641.35 µg/m<sup>3</sup> (0.916 ppm). This concentration is predicted to occur 228 m southeast of the steam superheater and auxiliary boiler stack (J-1) and does not exceed the allowable AAAQG of 1400 µg/m<sup>3</sup> (2.000 ppm) for NH<sub>3</sub>. Figure 2 shows the maximum predicted NH<sub>3</sub> concentrations over the entire modelling domain.

Table 4. Maximum predicted hourly average concentrations during normal operations at the JNO Plant.

Substance	NO <sub>2</sub>	NH <sub>3</sub>
Maximum Concentration (µg/m <sup>3</sup> )	169.0	641.4
Direction from Steam Superheater and Auxiliary Boiler Stack (J-1)	NW	SE
Downwind Distance from Flare (m)	5758	228

### Modelling Results for Normal Operating Conditions at CDT

The modelling results for normal operating conditions at the CDT are presented in Table 5. The maximum overall NO<sub>x</sub> concentration is 0.39 µg/m<sup>3</sup> (0.0002 ppm). This corresponds to an overall maximum predicted hourly average ground-level NO<sub>2</sub> concentration of 0.39 µg/m<sup>3</sup> (0.0002 ppm). This concentration is predicted to occur 190 m south-southeast of the CDT flare stack (C-1) and does not exceed the allowable AAAQG of 400 µg/m<sup>3</sup> (0.212 ppm) for NO<sub>2</sub>. Figure 3 shows the maximum predicted NO<sub>2</sub> concentrations over the entire modelling domain.

The maximum predicted hourly average ground-level NH<sub>3</sub> concentration is 1240.0 µg/m<sup>3</sup> (1.771 ppm). This concentration is predicted to occur 269 m northwest of the CDT flare stack (C-1) and does not exceed the allowable AAAQG of 1400 µg/m<sup>3</sup> (2.000 ppm) for NH<sub>3</sub>. Figure 4 shows the maximum predicted NH<sub>3</sub> concentrations over the entire modelling domain.

Table 5. Maximum predicted hourly average concentrations during normal operations at CDT.

Substance	NO <sub>2</sub>	NH <sub>3</sub>
Maximum Concentration (µg/m <sup>3</sup> )	0.39	1240.0
Direction from CDT Flare Stack (C-1)	SSE	NW
Downwind Distance from Flare (m)	190	269




Figure 1. Maximum predicted hourly average NO<sub>2</sub> concentrations associated with normal operation of the sources at the Agrium JNO Plant and the existing Nova and INEOS plants located within 7 km of LSD 07-03-039-25 W4M. Isopleths shown include 100, 125 and 150 µg/m<sup>3</sup>.




Figure 2. Maximum predicted hourly average  $\text{NH}_3$  concentrations associated with normal operating conditions of the sources at the Agrium JNO Plant, which is located at LSD 07-03-039-25 W4M. Isopleths shown include 100, 200 and 300  $\mu\text{g}/\text{m}^3$ .




Figure 3. Maximum predicted hourly average NO<sub>2</sub> concentrations associated with normal operations of the sources at the Agrium CDT, which is located at LSDs 07, 08, 09 and 10-34-040-25 W4M. Isopleths shown include 0.1 and 0.2 µg/m<sup>3</sup>.




Figure 4. Maximum predicted hourly average  $\text{NH}_3$  concentrations associated with normal operation of the sources at the Agrium CDT, which is located at LSDs 07, 08, 09 and 10-34-040-25 W4M. Isopleths shown include 500 and 1000  $\mu\text{g}/\text{m}^3$ .

### Modelling Results for Flaring Scenario No. 1 (Sphere Vapour Vent Flaring) at the CDT

When the ammonia pressure inside the ammonia sphere becomes too high, vapours from the sphere may be vented to the flare where they will be burned at an assumed 98% combustion efficiency before being released to the atmosphere. The flare modelling was processed with model parameters determined by the algorithms delineated by the Alberta Energy and Utilities Board (EUB) and included in the EUB spreadsheet entitled *Sour Well Test Flaring Permit Spreadsheet*. This spreadsheet enables the calculation of a flare pseudo-diameter, height and temperature for use in the model. These values are based on the heating value and flow rate of flared gas. These parameters yield the correct theoretical buoyancy for the emitted plume, which is required to create meaningful flare plume dispersion modelling.

Table 6 shows the flow rate and heating value used in this modelling scenario. The emission parameters generated by the EUB spreadsheet are based on the values shown in Table 6 and the physical stack height and diameter. The exit temperature of the flare stack is modified to reflect the increased buoyancy given to a plume containing significant concentrations of lighter than air molecules. This is the case for ammonia, whose molecular weight is 17.03 kg/kmol, compared to a molecular weight of 28.97 kg/kmol for standard dry air. This corrected temperature gives the emitted gas a more representative density and buoyancy.

Table 6. Emission pseudo-parameters used in the sphere vapour vent flaring scenario.

Flare ID	Heating Value (MJ/m <sup>3</sup> )	Flare Pseudo-Height (m)	Flow Rate <sup>(b)</sup> (10 <sup>3</sup> m <sup>3</sup> / day)	Flare Exit Temperature <sup>(c)</sup> (K)	Flare Pseudo-Diameter <sup>(c)</sup> (m)	Flare Velocity (m/s)
C-1	14.0	17.86	51.32	2368.6	0.710	21.41

<sup>(a)</sup> Effective release height of plume for ISC-PRIME modelling.

<sup>(b)</sup> At 15 °C and 101.3 kPa.

<sup>(c)</sup> Assumed for purposes of flare modelling as per AENV guidelines.

The modelling results for the sphere vapour vent flaring scenario are presented in Table 7. The maximum predicted one-hour ground level concentrations obtained for NO<sub>2</sub> and NH<sub>3</sub> are given along with their respective locations.

Table 7. Maximum predicted hourly average concentrations associated with the sphere vapour vent flaring scenario.

Substance	NO <sub>2</sub>	NH <sub>3</sub>
Maximum Concentration (µg/m <sup>3</sup> )	147.6	1291.4
Direction from CDT Flare Stack (C-1)	SSE	NW
Downwind Distance from Flare (m)	146	456

The maximum overall NO<sub>x</sub> concentration is 532.7 µg/m<sup>3</sup> (0.282 ppm). Using the Ozone Limiting Method as per the latest AENV Model Guideline, this corresponds to an overall maximum predicted hourly average ground-level NO<sub>2</sub> concentration of 147.6 µg/m<sup>3</sup> (0.078 ppm). This concentration is predicted to occur 146 m south-southeast of C-1 and does not exceed the allowable AAAQG of 400 µg/m<sup>3</sup> (0.212 ppm) for NO<sub>2</sub>. Figure 5 shows the maximum predicted NO<sub>2</sub> concentrations over the entire modelling domain.

The maximum predicted hourly average ground-level NH<sub>3</sub> concentration is 1291.4 µg/m<sup>3</sup> (1.845 ppm). This concentration is predicted to occur 456 m northwest of C-1 and does not exceed the allowable AAAQG of 1400 µg/m<sup>3</sup> (2.000 ppm) for NH<sub>3</sub>. Figure 6 shows the maximum predicted NH<sub>3</sub> concentrations over the entire modelling domain.

### Modelling Results for Flaring Scenario No. 2 (Rail Car Venting) at the CDT.

According to the original loading design for the CDT, the rail cars should be connected by vapour lines to the ammonia sphere where the displaced vapour is then recovered by a compressor. If this compressor failed to condense all the returning ammonia vapours, the excess vapour would be sent to the flare and burned at an assumed 98% combustion efficiency before being released to the atmosphere. However, this design option has never been implemented.

As previously described, the flare modelling was processed with model parameters determined by the algorithms delineated by the EUB and included in the EUB spreadsheet entitled *Sour Well Test Flaring Permit Spreadsheet*. The emission parameters generated by the EUB spreadsheet are based on the values shown in Table 8 along with the physical stack heights and diameters. Once again, the exit temperature of the flare was modified to reflect the increased buoyancy given to a plume containing significant concentrations of lighter than air molecules.

The modelling results for the rail car venting flaring scenario are presented in Table 9. The maximum predicted one-hour ground level concentrations obtained for NO<sub>2</sub> and NH<sub>3</sub> are given along with their respective locations.

Table 8. Emission pseudo-parameters as used in the rail car venting scenario.

Flare ID	Heating Value (MJ/m <sup>3</sup> )	Flare Pseudo-Height (a) (m)	Flow Rate (b) (10 <sup>3</sup> m <sup>3</sup> / day)	Flare Exit Temperature (c) (K)	Flare Pseudo-Diameter (c) (m)	Flare Velocity (m/s)
C-1	13.6	20.22	167.94	2353.6	0.709	69.93

(a) Effective release height of plume for ISC-PRIME modelling.

(b) At 15 °C and 101.3 kPa.

(c) Assumed for purposes of flare modelling as per AENV guidelines.

Table 9. Maximum predicted hourly average concentrations.

Substance	NO <sub>2</sub>	NH <sub>3</sub>
Maximum Concentration (µg/m <sup>3</sup> )	167.8	1417.9
Direction from the CDT Flare Stack (C-1)	SSE	SSE
Downwind Distance from Flare (m)	171	171




Figure 5. Maximum predicted hourly average  $\text{NO}_2$  concentrations associated with the sphere vapour vent flaring scenario at the Agrium CDT Facility, which is located at LSDs 07, 08, 09 and 10-34-040-25 W4M. Isopleths shown include 100 and 125  $\mu\text{g}/\text{m}^3$ .




Figure 6. Maximum predicted hourly average  $\text{NH}_3$  concentrations associated with the sphere vapour vent flaring sources at the Agrium CDT facility, which is located at LSD's 07, 08, 09 and 10-34-040-25 W4M. Isopleths shown include 500 and 1000  $\mu\text{g}/\text{m}^3$ .




Figure 7. Maximum predicted hourly average NO<sub>2</sub> concentrations associated with the rail car vent flaring scenario at the Agrium CDT Facility, which is located at LSDs 07, 08, 09 and 10-34-040-25 W4M. Isopleths shown include 50 and 100 µg/m<sup>3</sup>.




Figure 8. Maximum predicted hourly average  $\text{NH}_3$  concentrations associated with the rail car vent flaring scenario at the Agrium CDT Facility, which is located at LSDs 07, 08, 09 and 10-34-040-25 W4M. Isopleths shown include 500 and 1000  $\mu\text{g}/\text{m}^3$ .

The maximum overall NO<sub>x</sub> concentration is 734.4 µg/m<sup>3</sup> (0.389 ppm). Using the Ozone Limiting Method as per the latest AENV Model Guideline, this corresponds to an overall maximum predicted hourly average ground-level NO<sub>2</sub> concentration of 167.8 µg/m<sup>3</sup> (0.089 ppm). This concentration is predicted to occur 171 m south-southeast of C-1, and does not exceed the allowable AAAQG of 400 µg/m<sup>3</sup> (0.212 ppm) for NO<sub>2</sub>. Figure 7 shown on page 14 shows the maximum predicted NO<sub>2</sub> concentrations over the entire modelling domain.

As indicated in Figure 8 on the previous page, the maximum predicted hourly average ground-level NH<sub>3</sub> concentration is 1417.9 µg/m<sup>3</sup> (2.026 ppm). This concentration is predicted to occur 171 m south-southeast of C-1 and exceeds the allowable AAAQG of 1400 µg/m<sup>3</sup> (2.000 ppm) for NH<sub>3</sub>. However, it should be noted that over the course of the five year period included in the Red Deer meteorological data, there is only one instance of such exceedence. The exceedence only occurs with 56 km/h winds from the north-northwest and neutral stability and in the five-year period, this particular meteorological condition only occurred once. As such, the probability that this specific meteorology condition would occur at the same time as this flaring scenario is only about 0.0023% of the time. Moreover, Agrium can control the timing of this flaring scenario and therefore will ensure that no flaring will occur during these worst-case meteorological conditions. Such preventative action will eliminate the possibility of exceeding the AAAQG. The second highest predicted hourly average ground-level NH<sub>3</sub> concentration obtained from the model was 1388.3 µg/m<sup>3</sup> (1.983 ppm), which is within the allowable AAAQG.

The following additional information is provided for your reference:

- **Attachment A.** ISC-PRIME input and output files giving the overall maximum predicted concentrations for these scenarios.
- **Attachment B.** Windrose for the Red Deer Airport.

Thank you for the opportunity to work on this project. If you have any comments or questions, please contact me at (403) 547-7557, ext. 106 or by email at [barry.lough@calvinconsulting.ca](mailto:barry.lough@calvinconsulting.ca).

Yours truly,  
Calvin Consulting Group Ltd.



Barry J. Lough, Principal Meteorologist  
Air Quality & Regulatory Compliance Services

**ATTACHMENT A**

**Dispersion Modelling Input & Output Files**

# ISC-PRIME INPUT FILE – JOFFRE NITROGEN OPERATION PLANT

## NORMAL OPERATIONS NO<sub>x</sub>

### CO STARTING

TITLEONE AGrum Joffre - Renewal March 2007

MODELOPT DFAULT RURAL CONC

AVERTIME 1

POLLUTID NO<sub>x</sub>

TERRHGTS ELEV

RUNORNOT RUN

EVENTFIL EVENTEXP.INP

ERRORFIL ERRORS.OUT

### CO FINISHED

### SO STARTING

LOCATION FS749 POINT -2671.97 -1853.03 883.0  
LOCATION H101 POINT -2408.99 -1991.01 883.0  
LOCATION H102 POINT -2408.99 -1947.02 883.0  
LOCATION H103 POINT -2428.99 -1991.01 883.0  
LOCATION H104 POINT -2428.99 -1947.02 883.0  
LOCATION H105 POINT -2440.99 -1991.01 883.0  
LOCATION H106 POINT -2440.99 -1947.02 883.0  
LOCATION H107 POINT -2458.99 -1991.01 883.0  
LOCATION H108 POINT -2458.99 -1947.02 883.0  
LOCATION H109 POINT -2470.99 -1947.02 883.0  
LOCATION WHB601 POINT -2246.52 -1996.46 883.0  
LOCATION FB901A POINT -2400.38 -1884.47 883.0  
LOCATION FB901B POINT -2400.38 -1862.08 883.0  
LOCATION SH902A POINT -2388.69 -1955.56 883.0  
LOCATION SH902B POINT -2388.69 -1933.16 883.0  
LOCATION FS745 POINT -2680.97 -1703.04 883.0  
LOCATION H141 POINT -2499.98 -1693.04 883.0  
LOCATION H142 POINT -2457.99 -1683.04 883.0  
LOCATION H143 POINT -2499.98 -1683.04 883.0  
LOCATION H144 POINT -2457.99 -1663.04 883.0  
LOCATION H145 POINT -2499.98 -1663.04 883.0  
LOCATION H146 POINT -2457.99 -1636.05 883.0  
LOCATION H147 POINT -2499.98 -1636.05 883.0  
LOCATION H148 POINT -2457.99 -1617.05 883.0  
LOCATION H149 POINT -2499.98 -1617.05 883.0  
LOCATION H150 POINT -2457.99 -1604.05 883.0  
LOCATION H151 POINT -2499.98 -1604.05 883.0  
LOCATION WHB605 POINT -2436.41 -1667.32 883.0  
LOCATION FB905 POINT -2348.76 -1761.78 883.0  
LOCATION FS734 POINT -2621.43 -1758.85 883.0  
LOCATION 93S001 POINT -2737.31 -1567.99 883.0  
LOCATION FS761 POINT -2673.04 -1341.10 883.0  
LOCATION H210 POINT -2479.25 -1256.38 883.0  
LOCATION H220 POINT -2479.25 -1274.88 883.0  
LOCATION H230 POINT -2479.25 -1288.51 883.0  
LOCATION H240 POINT -2479.25 -1306.04 883.0  
LOCATION H250 POINT -2479.25 -1322.60 883.0  
LOCATION H260 POINT -2479.25 -1338.18 883.0  
LOCATION H270 POINT -2479.25 -1353.76 883.0  
LOCATION 51S001 POINT -2850.27 -1854.29 883.0  
LOCATION 63ME00 POINT -2960.30 -1458.93 883.0  
LOCATION 63ME01 POINT -2946.67 -1470.61 883.0  
LOCATION 105S00 POINT -2675.96 -1021.70 883.0  
LOCATION 105FH0 POINT -2333.18 -1090.83 883.0  
LOCATION CT101 POINT -2033.63 -1595.26 883.0  
LOCATION CT201 POINT -1998.39 -1595.26 883.0

LOCATION SB POINT -1961.82 -1613.76 883.0  
 LOCATION FS409 POINT -1957.30 -1219.37 883.0  
 LOCATION Q5980 POINT -1623.72 -1609.76 883.0  
 LOCATION F5901 POINT -1579.31 -1345.43 883.0  
 LOCATION F5902 POINT -1562.92 -1345.43 883.0  
 LOCATION F5601 POINT -1585.76 -1345.43 883.0  
 LOCATION F5907 POINT -1613.91 -1345.43 883.0  
 LOCATION Q5990 AREA -1562.08 -1504.98 883.0  
 LOCATION F5903 POINT -1570.63 -1319.52 883.0

LOCATION J1 POINT 0.00 0.00 880.0

\*\* Point Source QS HS TS VS DS  
 \*\* Parameters: ---- ---- ---- ---- ---

SRCPARAM FS749 0.054 77.65 1273.16 0.02 11.6  
 SRCPARAM H101 2.25 67.1 535.16 6.60 2.0  
 SRCPARAM H102 2.25 67.1 535.16 6.60 2.0  
 SRCPARAM H103 2.25 67.1 535.16 6.60 2.0  
 SRCPARAM H104 2.25 67.1 535.16 6.60 2.0  
 SRCPARAM H105 2.25 67.1 535.16 6.60 2.0  
 SRCPARAM H106 2.25 67.1 535.16 6.60 2.0  
 SRCPARAM H107 1.522 34.4 429.16 9.20 1.8  
 SRCPARAM H108 1.522 34.4 429.16 9.20 1.8  
 SRCPARAM H109 1.359 33.5 443.16 16.00 1.1  
 SRCPARAM WHB601 5.749 15.24 487.16 15.50 3.1  
 SRCPARAM FB901A 1.174 10.67 422.16 3.10 2.3  
 SRCPARAM FB901B 1.174 10.67 422.16 3.10 2.3  
 SRCPARAM SH902A 0.657 27.74 552.16 2.40 1.8  
 SRCPARAM SH902B 0.657 27.74 552.16 2.40 1.8  
 SRCPARAM FS745 0.096 77.65 1273.16 0.02 11.6  
 SRCPARAM H141 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H142 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H143 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H144 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H145 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H146 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H147 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H148 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H149 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H150 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM H151 1.568 33.5 460.16 16.60 1.1  
 SRCPARAM WHB605 9.038 19.5 422.16 17.40 3.1  
 SRCPARAM FB905 1.565 15.24 423.16 5.40 1.8  
 SRCPARAM FS734 0.0716 13.72 878.16 2.40 2.1  
 SRCPARAM 93S001 0.181 51.12 1273.16 0.01 8.6  
 SRCPARAM FS761 0.182 85.67 1273.16 0.06 8.6  
 SRCPARAM H210 2.617 61 423.16 7.60 2.6  
 SRCPARAM H220 2.617 61 423.16 7.60 2.6  
 SRCPARAM H230 2.617 61 423.16 7.60 2.6  
 SRCPARAM H240 2.617 61 423.16 7.60 2.6  
 SRCPARAM H250 2.617 61 423.16 7.60 2.6  
 SRCPARAM H260 2.617 61 423.16 7.60 2.6  
 SRCPARAM H270 2.617 61 423.16 7.60 2.6  
 SRCPARAM 51S001 0.528 56.7 1273.16 1.27 6.6  
 SRCPARAM 63ME00 0.096 10.67 453.16 2.00 1.1  
 SRCPARAM 63ME01 0.096 10.67 453.16 2.00 1.1  
 SRCPARAM 105S00 0.0683 51.26 1273.16 0.02 8.6  
 SRCPARAM 105FH0 0.182 17.3 1124.16 7.49 2.1  
 SRCPARAM CT101 10.046 45.7 355.16 21.00 5.5  
 SRCPARAM CT201 10.046 45.7 355.16 21.00 5.5  
 SRCPARAM SB 1.8055 19.8 422.16 14.68 1.4

SRCPARAM FS409 0.0751 13.72 877.16 2.21 2.1  
SRCPARAM Q5980 0.044444 61 891.16 91.40 1.0  
SRCPARAM F5901 1.256481 42.177 583.16 5.35 2.6  
SRCPARAM F5902 1.691898 42.177 581.16 4.28 2.6  
SRCPARAM F5601 0.472222 42.177 620.16 7.24 1.5  
SRCPARAM F5907 0.138889 34.747 532.16 2.73 1.0  
SRCPARAM Q5990 0.000053 0.5 13.45 13.45 0.0  
SRCPARAM F5903 0.041667 6.426 1143.16 0.72 1.0

SRCPARAM J1 1.296328 45.6 638.16 2.94 2.22

SO BUILDHGT J1 16.50 8.50 8.50 8.50 8.50 8.50  
SO BUILDHGT J1 8.50 8.50 8.50 11.00 11.00 16.50

.

.

SO YBADJ Q5980 0.00 0.00 0.00 0.00 0.00 0.00  
SO YBADJ Q5980 0.00 0.00 0.00 0.00 0.00 0.00

SRCGROUP ALL  
SO FINISHED

RE STARTING  
RE DISCCART -3300.0 5700.0 942.818  
RE DISCCART -3280.0 5700.0 943.021

.

.

RE DISCCART -2720.0 6300.0 948.830  
RE DISCCART -2700.0 6300.0 948.676  
RE FINISHED

ME STARTING  
INPUTFIL deer.met  
ANEMHGHT 10.  
SURFDATA 25000 1995  
UAIRDATA 23118 1995  
ME FINISHED

OU STARTING  
RECTABLE ALLAVE FIRST  
MAXTABLE ALLAVE 50  
PLOTFILE 1 ALL FIRST NOxL.xyz  
MAXIFILE 1 ALL 3047. NOxL.max  
OU FINISHED

ISC-PRIME OUTPUT FILE - JOFFRE NITROGEN OPERATION PLANT

NORMAL OPERATIONS NO<sub>x</sub>

1 \*\*\* ISC3P - VERSION 04269 \*\*\* \*\*\* AGrium Joffre - Renewal March 2007 \*\*\*  
\*\*\* \*\*\*

PAGE 44

\*\*MODELOPTs: CONC RURAL ELEV DFAULT

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF NOX IN MICROGRAMS/M\*\*3 \*\*

GROUP ID	DATE	NETWORK
	AVERAGE CONC (YYMMDDHH)	RECEPTOR (XR, YR, ZELEV, ZFLAG) OF TYPE GRID-ID

-----  
ALL HIGH 1ST HIGH VALUE IS 747.06842 ON 97061101: AT ( -3240.00, 5760.00, 944.27, 0.00) DC NA

\*\*\* RECEPTOR TYPES: GC = GRIDCART  
GP = GRIDPOLR  
DC = DISCCART  
DP = DISCPOLR  
BD = BOUNDARY

**ISC-PRIME INPUT FILE – JOFFRE NITROGEN OPERATION PLANT**

**NORMAL OPERATIONS NH<sub>3</sub>**

CO STARTING

TITLEONE AGrium Joffre - Renewal March 2007  
MODELOPT DFAULT RURAL CONC  
AVERTIME 1  
POLLUTID NH3  
TERRHGTS ELEV  
RUNORNOT RUN  
EVENTFIL EVENTEXP.INP  
ERRORFIL ERRORS.OUT

CO FINISHED

SO STARTING

LOCATION JNO1 AREA -56.6 -121.9 880.0  
SRCPARAM JNO1 0.00002098 3. 147.8 162.5 0.

SRCGROUP ALL

SO FINISHED

RE STARTING

RE DISCCART -160.0 -480.0 876.174  
RE DISCCART -140.0 -480.0 876.405

.  
.  
.

RE DISCCART 420.0 120.0 882.096  
RE DISCCART 440.0 120.0 882.387  
RE FINISHED

ME STARTING

INPUTFIL deer.met  
ANEMHGHT 10.  
SURFDATA 25000 1995  
UAIRDATA 23118 1995

ME FINISHED

OU STARTING

RECTABLE ALLAVE FIRST  
MAXTABLE ALLAVE 50  
PLOTFILE 1 ALL FIRST NH3L.xyz  
MAXIFILE 1 ALL 1400. NH3L.max

OU FINISHED

ISC-PRIME OUTPUT FILE - JOFFRE NITROGEN OPERATION PLANT

NORMAL OPERATIONS NH<sub>3</sub>

1 \*\*\* ISC3P VERSION 04269 \*\*\* \*\* AGrium Joffre - Renewal March 2007 \*\*\*  
\*\*\* \*\*

PAGE 31

\*\*MODELOPTs: CONC RURAL ELEV DFAULT

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF NH3 IN MICROGRAMS/M\*\*3 \*\*

GROUP ID	DATE AVERAGE CONC (YYMMDDHH)	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE	GRID-ID
----------	---------------------------------	--	---------	---------

-----

ALL HIGH 1ST HIGH VALUE IS 641.35315 ON 95120422: AT ( 140.00, -180.00, 878.84, 0.00) DC NA

\*\*\* RECEPTOR TYPES: GC = GRIDCART  
GP = GRIDPOLR  
DC = DISCCART  
DP = DISCPOLR  
BD = BOUNDARY

**ISC-PRIME INPUT FILE – CHIGWELL DISTRIBUTION TERMINAL**

**NORMAL OPERATIONS NO<sub>x</sub>**

STARTING CO STARTING

TITLEONE AGrium Chigwell - Renewal March 2007

MODELOPT RURAL CONC NOSTD

AVERTIME 1

POLLUTID NO<sub>x</sub>

TERRHGTS ELEV

RUNORNOT RUN

EVENTFIL EVENTEXP.INP

ERRORFIL ERRORS.OUT

CO FINISHED

SO STARTING

LOCATION c1 POINT 0.00 0.00 871.0

\*\* Point Source QS HS TS VS DS

\*\* Parameters: ---- ---- ---- ---- ---

SRCPARAM c1 0.000298 14.632 984.16 0.0027 4.616

SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	23.00
SO BUILDHGT C1	23.00	23.00	23.00	23.00	23.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	23.00
SO BUILDHGT C1	23.00	23.00	23.00	23.00	23.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDWID C1	29.58	29.58	28.68	26.91	24.33	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDWID C1	29.58	29.58	28.68	26.91	24.33	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDLN C1	29.58	29.58	28.68	26.91	24.32	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDLN C1	29.58	29.58	28.68	26.91	24.32	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	-59.17
SO XBADJ C1	-63.00	-64.92	-64.86	-62.83	-58.90	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	30.49
SO XBADJ C1	33.42	35.34	36.18	35.93	34.58	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	23.39
SO YBADJ C1	15.25	6.65	-2.16	-10.90	-19.31	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	-23.39
SO YBADJ C1	-15.25	-6.65	2.16	10.90	19.31	0.00

SRCGROUP ALL

SO FINISHED

RE STARTING  
RE DISCCART -300.0 -300.0 886.357  
RE DISCCART -280.0 -300.0 886.053  
.  
.  
RE DISCCART 280.0 300.0 858.173  
RE DISCCART 300.0 300.0 857.452  
RE FINISHED

ME STARTING  
INPUTFIL deer.met  
ANEMHGHT 10.  
SURFDATA 25000 1995  
UAIRDATA 23118 1995  
ME FINISHED

OU STARTING  
RECTABLE ALLAVE FIRST  
MAXTABLE ALLAVE 50  
PLOTFILE 1 ALL FIRST NOxE.xyz  
MAXIFILE 1 ALL 3047. NOxE.max  
OU FINISHED

ISC-PRIME OUTPUT FILE - CHIGWELL DISTRIBUTION TERMINAL

NORMAL OPERATIONS NO<sub>x</sub>

1 \*\*\* ISC3P - VERSION 04269 \*\*\* \*\*\* AGrium Chigwell - Renewal March 2007 \*\*\*  
\*\*\*

\*\*MODELOPTs: CONC RURAL ELEV PAGE 32  
NOSTD

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF NOX IN MICROGRAMS/M\*\*3 \*\*

GROUP ID	DATE AVERAGE CONC (YYMMDDHH)	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE	GRID-ID
----------	---------------------------------	--	---------	---------

-----  
ALL HIGH 1ST HIGH VALUE IS 0.39241 ON 96030608: AT ( 60.00, -180.00, 876.45, 0.00) DC NA

\*\*\* RECEPTOR TYPES: GC = GRIDCART  
GP = GRIDPOLR  
DC = DISCCART  
DP = DISCPOLR  
BD = BOUNDARY

**ISC-PRIME INPUT FILE – CHIGWELL DISTRIBUTION TERMINAL**

**NORMAL OPERATIONS NH<sub>3</sub>**

CO STARTING

TITLEONE AGrium Chigwell - Renewal March 2007  
MODELOPT RURAL CONC NOSTD  
AVERTIME 1  
POLLUTID NH3  
TERRHGTS ELEV  
RUNORNOT RUN  
EVENTFIL EVENTEXP.INP  
ERRORFIL ERRORS.OUT

CO FINISHED

SO STARTING

LOCATION CDT1 AREA -131.0 2.5 874.0  
LOCATION CDT2 AREA -78.4 17.4 871.0  
LOCATION CDT3 AREA -133.1 73.3 871.0

\*\* Area Source QS/A HS Xs Ys Angle

SRCPARAM CDT1 0.00007178 4. 170.4 23.7 26.093  
SRCPARAM CDT2 0.00007178 10. 86.1 72.9 26.093  
SRCPARAM CDT3 0.00007178 3. 72.5 41.5 26.093

SRCGROUP ALL

SO FINISHED

RE STARTING

RE DISCCART -480.0 -100.0 884.982  
RE DISCCART -460.0 -100.0 885.085

.

.

.

RE DISCCART 100.0 500.0 860.596  
RE DISCCART 120.0 500.0 860.210

RE FINISHED

ME STARTING

INPUTFIL deer.met  
ANEMHGHT 10.  
SURFDATA 25000 1995  
UAIRDATA 23118 1995

ME FINISHED

OU STARTING

RECTABLE ALLAVE FIRST  
MAXTABLE ALLAVE 50  
PLOTFILE 1 ALL FIRST NH3L.xyz  
MAXIFILE 1 ALL 1400. NH3L.max

OU FINISHED



ISC-PRIME INPUT FILE – CHIGWELL DISTRIBUTION TERMINAL

FLARING SCENARIO 1 – SPHERE VENT TO FLARE - NO<sub>x</sub>

CO STARTING  
TITLEONE AGrium Chigwell - Renewal March 2007  
MODELOPT RURAL CONC NOSTD  
AVERTIME 1  
POLLUTID NO<sub>x</sub>  
TERRHGTS ELEV  
RUNORNOT RUN  
EVENTFIL EVENTEXP.INP  
ERRORFIL ERRORS.OUT  
CO FINISHED

SO STARTING

LOCATION C1 POINT 0.00 0.00 871.0

\*\* Point Source QS HS TS VS DS  
\*\* Parameters: ---- ---- ---- ---- ---

SRCPARAM C1 4.4082 17.856 2367.32 21.41 0.71

SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	23.00
SO BUILDHGT C1	23.00	23.00	23.00	23.00	23.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	23.00
SO BUILDHGT C1	23.00	23.00	23.00	23.00	23.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDWID C1	29.58	29.58	28.68	26.91	24.33	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDWID C1	29.58	29.58	28.68	26.91	24.33	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDLN C1	29.58	29.58	28.68	26.91	24.32	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDLN C1	29.58	29.58	28.68	26.91	24.32	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	-59.17
SO XBADJ C1	-63.00	-64.92	-64.86	-62.83	-58.90	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	30.49
SO XBADJ C1	33.42	35.34	36.18	35.93	34.58	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	23.39
SO YBADJ C1	15.25	6.65	-2.16	-10.90	-19.31	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	-23.39
SO YBADJ C1	-15.25	-6.65	2.16	10.90	19.31	0.00

SRCGROUP ALL  
SO FINISHED

RE STARTING  
RE DISCCART -300.0 -300.0 886.357

RE DISCCART -280.0 -300.0 886.053

.

.

RE DISCCART 280.0 300.0 858.173

RE DISCCART 300.0 300.0 857.452

RE FINISHED

ME STARTING

INPUTFIL deer.met

ANEMHGHT 10.

SURFDATA 25000 1995

UAIRDATA 23118 1995

ME FINISHED

OU STARTING

RECTABLE ALLAVE FIRST

MAXTABLE ALLAVE 50

PLOTFILE 1 ALL FIRST NOxE.xyz

MAXIFILE 1 ALL 3047. NOxE.max

OU FINISHED

ISC-PRIME OUTPUT FILE - CHIGWELL DISTRIBUTION TERMINAL

FLARING SCENARIO 1 – SPHERE VENT TO FLARE - NO<sub>x</sub>

1 \*\*\* ISC3P - VERSION 04269 \*\*\* \*\*\* AGrium Chigwell - Renewal March 2007 \*\*\*  
\*\*\*

\*\*MODELOPTs: CONC RURAL ELEV NOSTD  
PAGE 32

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF NOX IN MICROGRAMS/M\*\*3 \*\*

GROUP ID DATE NETWORK  
AVERAGE CONC (YYMMDDHH) RECEPTOR (XR, YR, ZELEV, ZFLAG) OF TYPE GRID-ID  
-----

ALL HIGH 1ST HIGH VALUE IS 532.71252 ON 96102902: AT ( 40.00, -140.00, 875.02, 0.00) DC NA

\*\*\* RECEPTOR TYPES: GC = GRIDCART  
GP = GRIDPOLR  
DC = DISCCART  
DP = DISCPOLR  
BD = BOUNDARY

**ISC-PRIME INPUT FILE – CHIGWELL DISTRIBUTION TERMINAL**

**FLARING SCENARIO 1 – SPHERE VENT TO FLARE - NH<sub>3</sub>**

CO STARTING  
 TITLEONE AGrium Chigwell - Renewal March 2007  
 MODELOPT RURAL CONC NOSTD  
 AVERTIME 1  
 POLLUTID NH3  
 TERRHGTS ELEV  
 RUNORNOT RUN  
 EVENTFIL EVENTEXP.INP  
 ERRORFIL ERRORS.OUT  
 CO FINISHED

SO STARTING

LOCATION CDT1	AREA	-131.0	2.5	874.0
LOCATION CDT2	AREA	-78.4	17.4	871.0
LOCATION CDT3	AREA	-133.1	73.3	871.0

LOCATION C1	POINT	0.00	0.00	871.0
-------------	-------	------	------	-------

\*\* Area Source    QS/A    HS    Xs    Ys    Angle

SRCPARAM CDT1	0.00007178	4.	170.4	23.7	26.093
SRCPARAM CDT2	0.00007178	10.	86.1	72.9	26.093
SRCPARAM CDT3	0.00007178	3.	72.5	41.5	26.093

\*\* Point Source    QS    HS    TS    VS    DS

\*\* Parameters:    ----    ----    ----    ----    ---

SRCPARAM C1	8.3333	17.856	2368.6	21.41	0.710
-------------	--------	--------	--------	-------	-------

SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	23.00
SO BUILDHGT C1	23.00	23.00	23.00	23.00	23.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	23.00
SO BUILDHGT C1	23.00	23.00	23.00	23.00	23.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDWID C1	29.58	29.58	28.68	26.91	24.33	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDWID C1	29.58	29.58	28.68	26.91	24.33	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDLN C1	29.58	29.58	28.68	26.91	24.32	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDLN C1	29.58	29.58	28.68	26.91	24.32	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	-59.17
SO XBADJ C1	-63.00	-64.92	-64.86	-62.83	-58.90	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	30.49
SO XBADJ C1	33.42	35.34	36.18	35.93	34.58	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	23.39

SO YBADJ C1 15.25 6.65 -2.16 -10.90 -19.31 0.00  
SO YBADJ C1 0.00 0.00 0.00 0.00 0.00 0.00  
SO YBADJ C1 0.00 0.00 0.00 0.00 0.00 -23.39  
SO YBADJ C1 -15.25 -6.65 2.16 10.90 19.31 0.00

SRCGROUP ALL  
SO FINISHED

RE STARTING  
RE DISCCART -480.0 -100.0 884.982  
RE DISCCART -460.0 -100.0 885.085  
.  
.  
.  
RE DISCCART 100.0 500.0 860.596  
RE DISCCART 120.0 500.0 860.210  
RE FINISHED

ME STARTING  
INPUTFIL deer.met  
ANEMHGHT 10.  
SURFDATA 25000 1995  
UAIRDATA 23118 1995  
ME FINISHED

OU STARTING  
RECTABLE ALLAVE FIRST  
MAXTABLE ALLAVE 50  
PLOTFILE 1 ALL FIRST NH3L.xyz  
MAXIFILE 1 ALL 1400. NH3L.max  
OU FINISHED

ISC-PRIME OUTPUT FILE - CHIGWELL DISTRIBUTION TERMINAL

FLARING SCENARIO 1 – SPHERE VENT TO FLARE - NH<sub>3</sub>

1 \*\*\* ISC3P - VERSION 04269 \*\*\* \*\* AGrum Chigwell - Renewal March 2007 \*\*\*  
\*\*\* \*\*

\*\*MODELOPTs: CONC RURAL ELEV PAGE 34  
NOSTD

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF NH3 IN MICROGRAMS/M\*\*3 \*\*

GROUP ID	DATE AVERAGE CONC (YYMMDDHH)	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE	GRID-ID
----------	---------------------------------	--	---------	---------

-----  
ALL HIGH 1ST HIGH VALUE IS 1291.44495 ON 97012603: AT ( -360.00, 280.00, 872.86, 0.00) DC NA

\*\*\* RECEPTOR TYPES: GC = GRIDCART  
GP = GRIDPOLR  
DC = DISCCART  
DP = DISCPOLR  
BD = BOUNDARY

ISC-PRIME INPUT FILE – CHIGWELL DISTRIBUTION TERMINAL

FLARING SCENARIO 2 – RAIL CAR VENTING - NO<sub>x</sub>

CO STARTING  
TITLEONE AGrium Chigwell - Renewal March 2007  
MODELOPT RURAL CONC NOSTD  
AVERTIME 1  
POLLUTID NO<sub>x</sub>  
TERRHGTS ELEV  
RUNORNOT RUN  
EVENTFIL EVENTEXP.INP  
ERRORFIL ERRORS.OUT  
CO FINISHED

SO STARTING

LOCATION C1 POINT 0.00 0.00 871.0

\*\* Point Source QS HS TS VS DS  
\*\* Parameters: ---- ---- ---- ---- ---

SRCPARAM C1 14.655 20.224 2352.29 69.63 0.709

SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	23.00
SO BUILDHGT C1	23.00	23.00	23.00	23.00	23.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT C1	0.00	0.00	0.00	0.00	0.00	23.00
SO BUILDHGT C1	23.00	23.00	23.00	23.00	23.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDWID C1	29.58	29.58	28.68	26.91	24.33	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDWID C1	29.58	29.58	28.68	26.91	24.33	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDLN C1	29.58	29.58	28.68	26.91	24.32	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDLN C1	0.00	0.00	0.00	0.00	0.00	28.68
SO BUILDLN C1	29.58	29.58	28.68	26.91	24.32	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	-59.17
SO XBADJ C1	-63.00	-64.92	-64.86	-62.83	-58.90	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO XBADJ C1	0.00	0.00	0.00	0.00	0.00	30.49
SO XBADJ C1	33.42	35.34	36.18	35.93	34.58	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	23.39
SO YBADJ C1	15.25	6.65	-2.16	-10.90	-19.31	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	0.00
SO YBADJ C1	0.00	0.00	0.00	0.00	0.00	-23.39
SO YBADJ C1	-15.25	-6.65	2.16	10.90	19.31	0.00

SRCGROUP ALL  
SO FINISHED

RE STARTING  
RE DISCCART -240.0 -460.0 886.990

RE DISCCART -220.0 -460.0 886.656

.

.

RE DISCCART 340.0 140.0 858.209

RE DISCCART 360.0 140.0 858.233

RE FINISHED

ME STARTING

INPUTFIL deer.met

ANEMHGHT 10.

SURFDATA 25000 1995

UAIRDATA 23118 1995

ME FINISHED

OU STARTING

RECTABLE ALLAVE FIRST

MAXTABLE ALLAVE 50

PLOTFILE 1 ALL FIRST NOxL.xyz

MAXIFILE 1 ALL 3047. NOxL.max

OU FINISHED

ISC-PRIME OUTPUT FILE - CHIGWELL DISTRIBUTION TERMINAL

FLARING SCENARIO 2 - RAIL CAR VENTING - NO<sub>x</sub>

1 \*\*\* ISC3P - VERSION 04269 \*\*\* \*\*\* AGrium Chigwell - Renewal March 2007 \*\*\*  
\*\*\*

\*\*MODELOPTs: CONC RURAL ELEV NOSTD  
PAGE 33

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF NOX IN MICROGRAMS/M\*\*3 \*\*

GROUP ID	DATE AVERAGE CONC (YYMMDDHH)	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE	GRID-ID
----------	---------------------------------	--	---------	---------

-----  
ALL HIGH 1ST HIGH VALUE IS 734.42194 ON 96031508: AT ( 60.00, -160.00, 875.78, 0.00) DC NA

\*\*\* RECEPTOR TYPES: GC = GRIDCART  
GP = GRIDPOLR  
DC = DISCCART  
DP = DISCPOLR  
BD = BOUNDARY

ISC-PRIME INPUT FILE – CHIGWELL DISTRIBUTION TERMINAL

FLARING SCENARIO 2 – RAIL CAR VENTING - NH<sub>3</sub>

STARTING CO STARTING  
 TITLEONE AGrium Chigwell - Renewal March 2007  
 MODELOPT RURAL CONC NOSTD  
 AVERTIME 1  
 POLLUTID NH3  
 TERRHGTS ELEV  
 RUNORNOT RUN  
 EVENTFIL EVENTEXP.INP  
 ERRORFIL ERRORS.OUT  
 CO FINISHED

SO STARTING

LOCATION CDT1 AREA -131.0 2.5 874.0  
 LOCATION CDT2 AREA -78.4 17.4 871.0  
 LOCATION CDT3 AREA -133.1 73.3 871.0

LOCATION C1 POINT 0.00 0.00 871.0

\*\* Area Source QS/A HS Xs Ys Angle

SRCPARAM CDT1 0.00007178 4. 170.4 23.7 26.093  
 SRCPARAM CDT2 0.00007178 10. 86.1 72.9 26.093  
 SRCPARAM CDT3 0.00007178 3. 72.5 41.5 26.093

\*\* Point Source QS HS TS VS DS

\*\* Parameters: ---- ---- ---- ---- ---

SRCPARAM C1 27.7778 20.224 2353.62 69.93 0.709

SO BUILDHGT C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT C1 0.00 0.00 0.00 0.00 0.00 23.00  
 SO BUILDHGT C1 23.00 23.00 23.00 23.00 23.00 0.00  
 SO BUILDHGT C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT C1 0.00 0.00 0.00 0.00 0.00 23.00  
 SO BUILDHGT C1 23.00 23.00 23.00 23.00 23.00 0.00  
 SO BUILDWID C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID C1 0.00 0.00 0.00 0.00 0.00 28.68  
 SO BUILDWID C1 29.58 29.58 28.68 26.91 24.33 0.00  
 SO BUILDWID C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID C1 0.00 0.00 0.00 0.00 0.00 28.68  
 SO BUILDWID C1 29.58 29.58 28.68 26.91 24.33 0.00  
 SO BUILDLEN C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDLEN C1 0.00 0.00 0.00 0.00 0.00 28.68  
 SO BUILDLEN C1 29.58 29.58 28.68 26.91 24.32 0.00  
 SO BUILDLEN C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDLEN C1 0.00 0.00 0.00 0.00 0.00 28.68  
 SO BUILDLEN C1 29.58 29.58 28.68 26.91 24.32 0.00  
 SO XBADJ C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO XBADJ C1 0.00 0.00 0.00 0.00 0.00 -59.17  
 SO XBADJ C1 -63.00 -64.92 -64.86 -62.83 -58.90 0.00  
 SO XBADJ C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO XBADJ C1 0.00 0.00 0.00 0.00 0.00 30.49  
 SO XBADJ C1 33.42 35.34 36.18 35.93 34.58 0.00  
 SO YBADJ C1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO YBADJ C1 0.00 0.00 0.00 0.00 0.00 23.39

SO YBADJ C1 15.25 6.65 -2.16 -10.90 -19.31 0.00  
SO YBADJ C1 0.00 0.00 0.00 0.00 0.00 0.00  
SO YBADJ C1 0.00 0.00 0.00 0.00 0.00 -23.39  
SO YBADJ C1 -15.25 -6.65 2.16 10.90 19.31 0.00

SRCGROUP ALL  
SO FINISHED

RE STARTING  
RE DISCCART -240.0 -460.0 886.990  
RE DISCCART -220.0 -460.0 886.656  
.  
.  
RE DISCCART 340.0 140.0 858.209  
RE DISCCART 360.0 140.0 858.233  
RE FINISHED

ME STARTING  
INPUTFIL deer.met  
ANEMHGHT 10.  
SURFDATA 25000 1995  
UAIRDATA 23118 1995  
ME FINISHED

OU STARTING  
RECTABLE ALLAVE FIRST  
MAXTABLE ALLAVE 50  
PLOTFILE 1 ALL FIRST NH3L.xyz  
MAXIFILE 1 ALL 1400. NH3L.max  
OU FINISHED

ISC-PRIME OUTPUT FILE - CHIGWELL DISTRIBUTION TERMINAL

FLARING SCENARIO 2 – RAIL CAR VENTING - NH<sub>3</sub>

1 \*\*\* ISC3P - VERSION 04269 \*\*\* \*\* AGrium Chigwell - Renewal March 2007 \*\*\*  
\*\*\* \*\*

\*\*MODELOPTs: CONC RURAL ELEV NOSTD  
PAGE 34

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF NH3 IN MICROGRAMS/M\*\*3 \*\*


GROUP ID DATE NETWORK  
AVERAGE CONC (YYMMDDHH) RECEPTOR (XR, YR, ZELEV, ZFLAG) OF TYPE GRID-ID  
-----

ALL HIGH 1ST HIGH VALUE IS 1417.89587 ON 96031508: AT ( 60.00, -160.00, 875.78, 0.00) DC NA

\*\*\* RECEPTOR TYPES: GC = GRIDCART  
GP = GRIDPOLR  
DC = DISCCART  
DP = DISCPOLR  
BD = BOUNDARY

**ATTACHMENT B**

**Windrose for the Red Deer Airport**



Windrose for the Red Deer Airport.